

Beaumont Cherry Valley Water District
"B" Line Pipeline Replacement Project - Requests for Information

Request No.	Request Date	Request Subject/Description	District Response Date	District Response to Request
1	1/3/2022	Geotechnical Sampling: Will an encroachment permit be required for drilling for soil samples?	1/20/2022	Due to the drilling being located on District property, an encroachment permit will not be required for any work completed.
2	1/11/2022	How many copies of the proposal are required to be submitted?	1/11/2022	Page 10 of the RFP indicates the type and quantity to be submitted.
3	1/11/2022	Can a flash drive be submitted instead of a CD?	1/11/2022	Yes
4	1/18/2022	In the 30 limit page count are resumes and exhibits (forms) included?	1/20/2022	Yes, the 30 page limit includes all resumes and exhibits.
5	1/18/2022	A chart of Team certification acceptable, or are copies of Team certifications required?	1/20/2022	Either is acceptable, so long as all certifications are listed for each team member potentially participating in the project.
6	1/18/2022	Potholing was not identified as part of the scope of work and per the site visit it does not appear that potholing will be needed. Does the District foresee the need for potholing within the District's access road?	1/20/2022	There are no existing utilities in the District's access road; potholing will not be required for the location of other utilities. The existing waterline at the northern and southern points of connection will require surveying (to determine existing locations); District field staff can expose these connection locations for surveying. Coordination with District staff will need to occur prior to surveying.
7	1/18/2022	Would the District prefer a CD or Flash Drive copy of the proposal with the submittal?	1/18/2022	Either CD or Flash Drive will be sufficient