

Beaumont Cherry Valley Water District

Design and Engineering Services for The 2022/2023 Water Storage Tank Recoating, Painting and Rehabilitation Projects - Requests for Information

Request No.	Request Date	Request Subject/Description	District Response Date	District Response to Request
1	5/12/2022	The inspection report for Cherry Valley No. 2 recommended interior coating replacement, should this work be included in the scope of work?	5/12/2022	The District is aware of the recommended interior coating replacement for Cherry Valley No. 2 and anticipate recoating both Cherry 1 and Cherry 2 during a future project. For this RFP, the District is only looking at exterior paint for Cherry No. 2.
2	5/12/2022	Is there a project or construction budget established for this project? If so, can that be shared?	5/12/2022	The District does not have a projected construction cost at this time. After a construction RFP is created, staff will advertise the project for construction and take the findings to the Board of Directors for consideration.
3	5/16/2022	Task A - Project Coordination and Task I - Project Management appear to be very similar. We were planning to combine these items into just Task A, is that acceptable?	5/17/2022	Please include a proposed cost for both Section III.A. - Project Coordination and Section III.H.1. - Project Management separately as identified in the RFP
4	5/16/2022	We understand the project includes the interior coating replacement for the Lower Edgar Tank, please confirm.	5/17/2022	Yes, the Lower Edgar Tank includes interior coating replacement.
5	5/16/2022	Can the District provide an estimate of how many days the certified inspector will be needed as the basis of the proposal so that all proposals can be judged on an equal basis?	5/17/2022	As an estimate, please use 10 days for the certified inspector as the basis of the proposal. Additionally, provide a daily rate should the inspections require more than 10 days.
6				
7				