

REQUEST FOR INFORMATION LOG

Organization Name:		Beaumont-Cherry Valley Water District		
Project Name:		2017 Water Pipeline Replacement Project - Pipeline 1 (P-3620-0012)		
Project Manager:		Mark Swanson		
Last Updated:		6/28/2022		
No.	RFI Date	Date Answered	Description of RFI	Response to RFI
1	6/27/2022	6/28/2022	Are bid bonds required for a bid package to be considered complete?	No. Bid bonds are not required for this Project.
2	6/27/2022	6/28/2022	What are the pavement replacement limits for the project? Is grind and overlay required, or is only temporary pavement required? How much concrete replacement is required vs amount of asphalt pavement replacement?	Per this Contract, the Contractor is expected to fully replace disturbed pavement (concrete or asphalt concrete pavement) with public R/W per County of Riverside standards. Replacement of privately owned pavement shall be in-kind and grind and overlay to match existing pavement.
3	6/27/2022	6/28/2022	What is considered suitable native material? What are contractor requirements for backfilling over pipe zone (is compaction testing a responsibility of the contractor or is the District responsible for compaction testing)?	Determination of suitable backfill material and compaction limits will be determined by the District's geotechnical consultant for this project.
4	6/27/2022	6/28/2022	What are the contractor's responsibilities for replacing grass/trees/miscellaneous landscaping?	Grass/trees/landscaping shall be replaced in-kind; however, Contractor shall work around trees so that none are lost during construction. Contractor shall coordinate with District Field Staff regarding replacement of damaged private irrigation (i.e. pipes, fittings).
5	6/27/2022	6/28/2022	Will construction staking be completed? Is the contractor responsible for construction staking, or is the District responsible for construction staking?	The District will utilize its design engineer for survey staking. The engineer and/or surveyor will be in attendance at the pre-construction meeting.
6				
7				
8				
9				
10				
11				